

STATE OF NORTH CAROLINA
DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF WATER QUALITY

PERMIT

TO DISCHARGE WASTEWATER UNDER THE
NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM

In compliance with the provision of North Carolina General Statute 143-215.1, other lawful standards and regulations promulgated and adopted by the North Carolina Environmental Management Commission, and the Federal Water Pollution Control Act, as amended,

Champion International Corporation

is hereby authorized to discharge wastewater from a facility located at

Champion Canton Mill Wastewater Treatment Plant
off Highway 215
Canton
Haywood County

to receiving waters designated as the Pigeon River in the French Broad River Basin

in accordance with effluent limitations, monitoring requirements, and other conditions set forth in Parts I, II, III, and IV hereof.

The permit shall become effective

This permit and the authorization to discharge shall expire at midnight on November 30, 2001.

Signed this day

FINAL DRAFT *

A. Preston Howard, Jr., P.E., Director
Division of Water Quality



By Authority of the Environmental Management Commission

* NOTE: Δ 'S FROM 1ST DRAFT ARE NOTED IN BOLD.
ALSO, BOILERPLATE IS NOT INCLUDED.



ROAD CLASSIFICATION	
PRIMARY HIGHWAY HARD SURFACE	LIGHT-DUTY ROAD, HARD OR IMPROVED SURFACE
SECONDARY HIGHWAY HARD SURFACE	UNIMPROVED ROAD

Lat: 35°32'08" Long: 82°50'42"
 Map # E7SE Sub-basin 04-03-05
 Stream Class C
 Discharge Class Industrial/ Domestic
 Receiving Stream Pigeon River
 Qw: 29.9 Permit exp. 11/30/01



Champion International
 Canton Mill WWTP
 NC0000272
 Haywood County

During the period beginning on the effective date of the permit and lasting until expiration of the permit, the Permittee is authorized to discharge from outfall(s) serial number 001. Such discharges shall be limited and monitored by the permittee as specified below:

Effluent Characteristics	Discharge Limitations			Monitoring Measurement Frequency	Sample Type	Requirements	
	Lbs/day	Units (Specify)	Sample Location				
	Mon. Avg.	Daily	Max.	Mon. Avg.	Daily	Max.	
Trichlorophenol				Quarterly	Composite		E
Pentachlorophenol				Quarterly	Composite		E
Zinc				2/Month	Composite		E
Cadmium				Quarterly	Composite		E
Selenium				Quarterly	Composite		E
Silver				Quarterly	Composite		E
AOX				Monthly	Composite		E
2,3,7,8 Tetrachloro-dibenzo-p-dioxin (See Part III, Condition H)			0.1 pg/l	Quarterly	Composite		E
Color (See Part III, Condition E)				Daily	Composite		E, I
Conductivity				Daily	Grab		E
pH				Daily	Grab		E